



NOTES: 1) ALL VALVES ARE GATE TYPE
 2) THERMOWELL INSERTION IS TO MIDDLE OF FIXED VOLUME CYLINDER

TAG# VP-SO-21

MAX DESIGN PRESSURE: 500 PSIG
 MAX DESIGN TEMP: 730°F
 WETTED PARTS: 316/316LSS / GRAPHOIL
 HYDROTEST PRESSURE: 750 PSIG

Same comment as in VP-SO-22

2-3" High

IS this the HU sample valve?

previous proposal was showing HU sample valve

Sample can

3/4" FNPT FOR FUTURE EDUCATOR

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF SOR. NO USE WHATSOEVER OF THE INFORMATION CONTAINED HEREON, NOR REPRODUCTION IN WHOLE OR PART MAY BE MADE WITHOUT THE EXPRESS WRITTEN PERMISSION OF SOR.

TOLERANCES: (UNLESS OTHERWISE SPECIFIED) FRACTIONS: +/- 1/8" ALL DIMENSIONS ARE IN INCHES NO BURNS OR SHARP EDGES

ENGINEER APPROVAL

5175 Ashley Court
 Houston, Texas 77041
 913-988-2630 SORINC.COM

TITLE FIXED-VOLUME SAMPLE SYSTEM			
MATERIAL SS	DATE 5-29-19	REV 2	DWG SIZE A
SCALE N.T.S.	DRAWING NUMBER SSO-003451		
DO NOT SCALE PRINT			

Model Name: BBSS